

DAILY INSPECTION REPORT ALARM KEBAKARAN AUTOMATIK

Tanggal Pemeriksaan : 8 April 2026

Instalasi : Alarm Kebakaran Automatik

Pemilik : PT MULTI SPUNINDO JAYA Tbk

Lokasi : All Gedung PT MULTI SPUNINDO -JAYA

No.	Pictures	Descriptions	Findings	Recommendations	Follow-Up	HC*
1.	  	Pemeriksaan visual pada main control fire alarm & Annunciator fire alarm				
2.	  	Pemeriksaan visual dan pengujian pada : - Manual call point - Bell alarm - Indicator lamp	Kondisi baik	-	-	-

No.	Pictures	Descriptions	Findings	Recommendations	Follow-Up	HC*
3.	    	Pemeriksaan visual dan pengujian pada smoke detektor dan heat detektor	Kondisi berfungsi dengan baik	-	-	-

Kesimpulan:

- Secara umum, Instalasi Alarm Kebakaran Otomatis yang terpasang di All Gedung PT MULTI SPUNINDO JAYA Tbk memenuhi syarat Keselamatan dan Kesehatan Kerja (K3) untuk dioperasikan dengan memperhatikan dan segera menindaklanjuti saran-saran yang diberikan.

Keterangan :

HC * (Hazard Classification)

- A : a condition or practice likely to cause permanent disability, loss of life or body part, and/ or extensive loss of structure, equipment or material
B : a condition or practice likely to cause serious injury or illness, resulting in temporary disability or property damage that is disruptive but not extensive
C : a condition or practice likely to cause minor, non-disabling injury or illness, or non-disruptive property damage

PT MULTI SPUNINDO JAYA Tbk

Sidoarjo, 8 April 2026
PT ADIKA ATMAJA TEKNIK

Farid Nur Hamzah
Inspector